



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DG-5126AU0320

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	WILLBRANDT KG Reinhold-Schleese-Straße 22, D-30179 Hannover
Distributor <i>Vertreiber</i>	WILLBRANDT KG Reinhold-Schleese-Straße 22, D-30179 Hannover
Product Category <i>Produktart</i>	greasing and sealing materials: Flat sealing materials for gas installation, with higher thermal resistance (5126)
Product Description <i>Produktbezeichnung</i>	flat sealing material on synthetic fiber basis with higher thermal resistance
Model <i>Modell</i>	GASFALIT, DVGW, KTW, HTB, VP 401
Test Reports <i>Prüfberichte</i>	laboratory control test: 17/131/5126/08WH from 30.05.2017 (EBI)
Test Basis <i>Prüfgrundlagen</i>	DVGW VP 401 (01.10.1998)

Date of Expiry / File No. 30.06.2020 / 17-0395-GNV
Ablaufdatum / Aktenzeichen

28.06.2017 Rie A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
GASFALIT, DVGW, KTW, HTB, VP 401	pressure range: 1...5 bar	depending on the application

certified Components**zertifizierte Bauteile / Werkstoffe**

Registr. No. <i>Registrier-Nr.</i>	Component <i>Bauteil (Produktart)</i>	Model/Type <i>Modell/Typ</i>	Manufacturer <i>Hersteller</i>
NG-5123BP0248	Flat sealing materials on synthetic fiber basis	novapress® BASIC/novapress® BASIC	Frenzelit GmbH
NG-5123BP0349	Flat sealing materials on synthetic fiber basis	GASFALIT/GASFALIT	WILLBRANDT KG

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

Field of application for pressure range ≤ 1 bar: gas meters with two-pipe- and one-pipe-screw connections according to DIN 3376-1, DIN 3376-2 or with flange connections according to DIN 3376-2

Field of application for pressure range ≤ 5 bar: pressure regulators with screw connections according to DIN 2993, DIN 3376-1, DIN 3376-2 and DIN EN 10242 as well as pressure regulators and turning piston gas meters with flange connections according to DIN 2543, DIN 2633, DIN 3376-2, DIN EN 1092-1 and DIN EN 1092-2