



DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NG-5117DQ0444

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	WILLBRANDT KG Reinhold-Schleese-Straße 22, D-30179 Hannover
Distributor <i>Vertreiber</i>	WILLBRANDT KG Reinhold-Schleese-Straße 22, D-30179 Hannover
Product Category <i>Produktart</i>	Greasing and sealing materials: Sealing material and HTB resistant seals for the gas installation (5117)
Product description <i>Produktbezeichnung</i>	Sealing material and HTB-resistant seals for gas installations
Model <i>Modell</i>	WILLBRALIT®
Test reports <i>Prüfberichte</i>	Type testing: 24-00360-AB01 from 27.02.2025 (EBI)
Test basis <i>Prüfgrundlagen</i>	DIN 30653 (01.08.2018)- as far as applicable

Date of Expiry / File No. 27.02.2030 / 25-0307-GNE
Ablaufdatum / Aktenzeichen

25.07.2025 Bd A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

J. Schmidt



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-00

DVGW CERT GmbH
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 9188-888
info@dvwg-cert.com
www.dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
WILLBRALIT®	Thickness: 2 mm Pressure range: 0,1 bar	

Hints of Utilization / Remarks***Verwendungshinweise / Bemerkungen***

Application area for a maximum operating pressure of 0.1 bar: screw connections of gas meters according to DIN 3376-1

